

El Paso Leadership Academy
RFP 2021-003 Low Voltage
Amendment 2

Extension to RFP

Deadline to submit RFP has been extended to Tuesday, February 2, 2021 at 2:00PM MST

Questions from Pre Bid Meeting

1. Do we want a predictive design or have we identified where we want our access points? (I thought that this work had been done with the help of Scott Adkins and Rene Melendez but I didn't see this doc in exhibit H.) Per Exhibit F - Scope of Services, Item 1.c indicates the Offeror is to “Design and install a Wireless Access Point system to provide full coverage of the entirety of the building.” The Offeror should reference Exhibit H - Project Documents for their use.
2. Approximately when will low voltage be installed? Anticipated installation start date would be May 2020. Coordination with the Design-Builder’s CPM schedule will be required. The date is subject to change.
3. Does the RFP include power requirements for a UPS to run every 15 minutes? Yes. Per Exhibit G - Cabling Guidelines and Specifications, Item 1.e.i indicates that the UPS should be “Sized to support up to 15-minute run time for all rack-mounted equipment.”
4. How many users will network need to support? Approximately 832 students and 50 staff
5. Does the low voltage RFP include data drops for our security system or is that outlined in the Security Systems RFP? This RFP does not include any cabling for the Security Systems as the equipment locations are not identified on Exhibit H - Project Documents. The cabling for Security Systems is to be provided by the awarded Security Systems Contractor per RFP #2021-004.

Follow up questions will be accepted through Friday, January 22, 2021 at 12pm. Responses will be posted on our website.